

National High Speed Rail Corporation Limited
(A Joint Sector Company of Govt. of India and Participating State Government)
3rd floor, Riverfront house, Usmanpura, Near Gandhi Bridge, Ahmedabad- 380009

Date: 04.06.2019

NIT no. & dt. NHSRCL(ADI)/MA/EL02/USML/86.1, dtd. 17.05.2019.

Following are to be considered:

S. No	Refer Para No.	Original	Revised
1	Notice Inviting Tender, para no. 8(a), INITIAL REQUIREMENTS Sr.no. 9	NIL	Contractor should have valid electrical contractor license.
2.	Instructions to tender (IIT), para no. 2 (A) 1.2, The bidder should accompany the following documents dully sealed in the tender envelop: Technical Bid (Packet-I) (ix)	NIL	Contractor shall submit valid electrical contractor license.
3.	Technical specifications	NIL	Technical specifications for supply of various 11kV XLPE cables (item no. 50 to 55): The contractor have to supply of 'ISI marked', HT XLPE insulated & PVC sheathed, armoured, 11 KV grade, aluminum cables of sizes as mentioned in schedule of rates & quantity and confirming to IS: 7098(part-1:1988) or latest. Make- Polycab, Asian, Nicco, Finolex, Bharatcab, RR Kabel, Havells, Avocab, L&T, Anchor, Pyroflex, Paragon, CCI, HPL make's only. In case of full drum length of the cable, the contractor has to offer for testing and inspection of cable at manufacturer's works for which all arrangement i.e. fixing of time & date with manufacturer, arranging testing instruments, etc. shall have to be made by contractor at his own cost. The cable shall be tested in accordance with IE rules and relevant IS & standard code of practice.

Place: Ahmedabad

Date: 04.06.2019

Handwritten signature and date:
4/6/19

